

ADDENDUM #1

**SENECA COUNTY WATER AND SEWER AUTHORITY
REQUEST FOR PROPOSALS #2026-01**

PUMP STATION MAINTENANCE – SEWER DISTRICTS 3 AND 4

The following ADDENDUM is offered to the above-referenced Request for Proposals. Exclusive of the change noted below, all other information, descriptions, and directions remain intact for the purposes of this RFP.

CLARIFICATION – APPENDIX C

The checklist offered in Appendix C requires that the offeror and subsequent awardee commit to “clean grease and or rag buildup within wet well” on each visit as needed.

This item does not require, as part of Bid Item #1, the offeror/awardee to address/correct such buildup such that a Vac Truck or similar heavy equipment be needed to clear the obstruction. Such work would be performed under Bid Items #2, 3, and 4.

- END CLARIFICATION –

For additional information, please follow contact instructions outlined in the Request for Proposals.

ISSUED: March 24, 2026